

**BOROUGH OF CHAMBERSBURG GAS DEPARTMENT  
80 SOUTH FRANKLIN STREET  
CHAMBERSBURG, PA 17201  
(717) 263-4111**

**COMMERCIAL / INDUSTRIAL GAS UTILIZATION APPLICATION**

Is this a new service? YES NO (circle one)

\* IS THIS A HEATING UNIT \_\_\_\_\_ OR SOURCE \_\_\_\_\_

**PART I**

Sec. 1a: To be completed by mechanical/heating contractor:

Name of mechanical/heating contractor: \_\_\_\_\_

Address: \_\_\_\_\_ Phone No. \_\_\_\_\_

b: To be completed by fuel piping installer: (if different from above)

Name of fuel piping installer: \_\_\_\_\_

Address: \_\_\_\_\_ Phone No. \_\_\_\_\_

Sec. 2a: Installation for: \_\_\_\_\_  
Address: \_\_\_\_\_ Phone No. \_\_\_\_\_

b: Equipment to be Installed:

1. Type: \_\_\_\_\_ Manufacturer: \_\_\_\_\_ Model No. \_\_\_\_\_  
No. of Units: \_\_\_\_\_ Btu Input: \_\_\_\_\_ Pressure Required: \_\_\_\_\_

2. Type: \_\_\_\_\_ Manufacturer: \_\_\_\_\_ Model No. \_\_\_\_\_  
No. of Units: \_\_\_\_\_ Btu Input: \_\_\_\_\_ Pressure Required: \_\_\_\_\_

3. Type: \_\_\_\_\_ Manufacturer: \_\_\_\_\_ Model No. \_\_\_\_\_  
No. of Units: \_\_\_\_\_ Btu Input: \_\_\_\_\_ Pressure Required: \_\_\_\_\_

4. Type: \_\_\_\_\_ Manufacturer: \_\_\_\_\_ Model No. \_\_\_\_\_  
No. of Units: \_\_\_\_\_ Btu Input: \_\_\_\_\_ Pressure Required: \_\_\_\_\_

Sec. 3a: Type of fuel pipe to be run: \_\_\_\_\_ Size: \_\_\_\_\_  
Length: \_\_\_\_\_ (if necessary include line schematic)

Sec. 4a: Total Btu/hr. Input required: \_\_\_\_\_ Gas Pressure Required: \_\_\_\_\_

b: Installation Date: \_\_\_\_\_ Completion Date: \_\_\_\_\_

When project is complete, contact Service Center for inspection of installation, fuel piping and venting. All installations are to be in accordance with the latest version of the National Fuel Gas Code or Borough Regulations, whichever are more stringent, as well as manufacturers recommendations.

Contractor: \_\_\_\_\_ Date: \_\_\_\_\_  
Signature

**PART II:**      To be completed by Gas Department Personnel

Sec.    1a:    **Installation for:** \_\_\_\_\_  
                 **Address:** \_\_\_\_\_ **Phone No.:** \_\_\_\_\_

                 b:    **Class of Service:**            321 { }        331 { }        342-342 { }        361 { }

Sec.    2a:    **Does equipment installation agree with information on reverse side?**        Y { }    N { }

**Does piping installation agree with information on reverse side?**        Y { }    N { }

**Does area have adequate supply of fresh air?**        Y { }    N { }

**Is equipment adequately and properly vented?**        Y { }    N { }

**Is equipment installed properly?**        Y { }    N { }

**Was fuel line piping leak free at time of connection?**        Y { }    N { }

**Method of testing the above:** \_\_\_\_\_

**Remarks: If answer is NO to any of the above explain.** \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

Sec.    3a:    **Is new/replacement service required?**        Y { }    N { }  
                 **If so, make One-Call**

                 b:    **Meter size required:** \_\_\_\_\_ **Regulator size required:** \_\_\_\_\_  
                 **Relief size required:** \_\_\_\_\_

**This application shall not be construed as imposing upon the Borough of Chambersburg any liability or responsibility for damages to any person injured by any defect in any gas piping or appliance mentioned herein, or by the installation thereof, nor shall the Borough, or any official or employee thereof, be held as assuming any such liability or responsibility by reason of the inspection authorized hereunder or the certificate of approval issued by the inspector.**

**Inspected by:** \_\_\_\_\_

**Date:** \_\_\_\_\_

## **Borough of Chambersburg**

### **Requirements for Installation of Commercial or Industrial Gas Piping**

All new commercial or Industrial gas piping installations in the Borough of Chambersburg must meet the following requirements. Any questions regarding these or any other requirements should be addressed to the Gas Supervisor.

1. Any gas piping to be installed larger than 2" must be welded.
2. If system is to be operated with gas at a pressure greater than 5 psi all piping shall be welded.
3. Regulators will be vented to the outside unless equipped with an approved vent limiter.
4. Any piping passing through a wall or floor or in contact with concrete or other masonry material shall be sleeved.
5. All piping shall be properly supported as required by its size, length and type.
6. Sediment traps shall be installed in piping where condensate will collect.
7. Piping installations will require a 24 hour 50 psi air test that is chart recorded by Borough Gas Department personnel.
8. Any piping that has not been used for a year must be air tested (per item 7 above) prior to being put back into operation.